

தீயணைப்பு மற்றும் அவசர மீட்பு பிரிவு - நகராட்சிமன்றம், திருகோணமலை
கீழ் கிணைப்பு கட்டிடம் உட்கட்டுவதற்கான அனுமதி - கனம் கனாவி, திருகோணமலை
FIRE AND RESCUE UNIT- URBAN COUNCIL, TRINCOMALEE

05th June of 2025

Sri Hari Hara Puthira Iyanar Thiru Kovil
Harbour Road, 5th Ward, J/38
Analaitivu West, Jaffna.

Reference your application dated 04/06/2025 regarding above.

The set of plans have been examined by me and the same is recommended subject to the compliance with the requirements as stipulated in this letter.

1. Permitted openings

No openings are permitted in external walls on or within 1 m of the boundary.

2. Fire Resistance

Minimum period of fire resistance for the elements of structure to be not less than 1 hour.

3. Fire Plan for Proposed Renovation for Existing Temple building.

Ground floor

9 Ltr. Water fire extinguisher	-	04No's
3 Kg Carbon dioxide fire extinguisher	-	04No's
19mm X 30m hose reel system	-	02No's
Manual Fire Alarm Call point	-	01No's
Fire Alarm with Strobe light	-	02No's
Exit Sign Boards Illuminated type	-	01No's

Exit signs

01 No's exit sign board's illuminated type with directional marks should be installed at exit positions at each floor level.

Hose reel System

- (a) 02 X 19mm X 30m Hydraulic Hose Reel, permanently connected to a hose reel main with a shut off nozzle, providing 30 L/min, with a 6m throw to be installed as shown in the plan.
- (b) The capacity of the underground tank supplying water to the installation shall not be less than 6000 liters and be fed automatically by town's main or a reliable source.
- (c) If tank supplying water for domestic purpose is used as suction tank arrangements shall be made for these domestic supplies to be drawn off in such a manner that the requisite reserve of water for firefighting is always preserved

4. Means of Giving Warning

- (a) A Manually operated 02 Nos fire alarm system with 01 Nos. release button call points should be installed as shown in the plan.
- (b) The warning shall be distinctive and must be sited so as to ensure warning throughout the building.
- (c) All cables and conductors shall be enclosed throughout in protective covering of material of adequate strength, to resist mechanical damage.



தீயணைப்பு மற்றும் அவசர மீட்பு பிரிவு - நகராட்சிமன்றம், திருகோணமலை
கிதி கிபிண ஈண னபீசி ஓடா ஁தீ஁ ஁஁஁ - ஁஁஁ ஁஁஁, திருகோணமலை

FIRE AND RESCUE UNIT- URBAN COUNCIL, TRINCOMALEE

5. Access route

(a) Gateway to the premises shall not be less than 3 m wide.

(b) Access road of hard standing 4 m wide and 4 m clear height for a 15-ton pumping appliance to be provided along one perimeter wall of the building.

6. The fire emergency escape

The fire emergency escape as shown in the plan must be connected, alternative means of escape system is required.

7. In General

No further extensions in the structure are permitted without obtaining the prior approval of the fire brigade

Before issuing the certificate of conformity by the Trincomalee Fire and Rescue Unit, Fire precaution, Adequacy inspection shall be carried out by the fire officer In Charge of the Trincomalee Fire Brigade. The approval plan should be made available at the time of the time inspection for reference.

Thanking You,
Yours faithfully,



D.K. Weerakoon
Section Fire Officer
Fire & Rescue Unit
Urban Council
Main Street, Trincomalee.

